

Compliance Statement

No. 2025-008

Data communication cords, Category 6A

Company

KRUGEL EXIM spol. s r.o. Pri majeri 13 831 06 Bratislava Slovak Republic

Product description

Screened Category 6_A RJ45 cords (equipment, patch, and work area) characterised up to 500 MHz

Product identification

Keline 10Giga patch cables STP Cat.6A, LS0H

Part number: KEL-C6A-P-xxx (xxx: denotes length in dm)

Generic cabling and cabling components standard - Category 6A balanced cord requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018
- IEC 61935-2:2022 (Ed. 4.0) (transmission requirements)

Lindolen Reduce

Technical report

12433234-01, DANAK-19/24729

EC Cabling product ID

5008

CS valid until 1 March 2026

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 14 January 2025

Lars Lindskov Pedersen

Test Manager

Dennis Andersen Head of Department

