

Certificate

No. c9252a-25

Customer:

Krugel Exim spol. s r.o. Pri majeri 13 831 06 Bratislava 35, Slovakia

Test sample(s):

Connecting hardware:
Keline® RJ-45 Keystone Cat.6A
Part no.: KEJ-C6A-S-HD

Category 6A

Applied standard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)
DIN EN 50173-1 (2018-10)
ANSI/TIA-568.2-D (2018-09)
IEC 60603-7-51 Ed.1.0 (2010-03)

Result(s):

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

Connecting hardware, Copper, Category 6A

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report **no. R9252a-25** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of testing.

Bexbach, 19. February 2025

Dirk Wilhelm, engineer (Chairman of the Managing Board)

CHMI TANDAGA JANI . TAVORGO JANI . JANORGO JANI . J

GHMT AG

In der Kolling 320 66450 Bexbach / Germany

PO box 11 16 66442 Bexbach / Germany

T: +49 6826 92 28-0 F: +49 6826 92 28-290

info@ghmt.de www.ghmt.de

RELIABILITY IN TOTAL
REOUIRES ACCURACY IN DETAIL.

Test laboratory accredited by DAkkS in accordance with DIN EN ISO/IEC 17025:2018. The accreditation is valid for the test methods listed in certificate D-PL-17559-01-00.